



**Dominion**

# DAM INSPECTION CHECKLIST POSSUM POINT POWER STATION POND ABC

INSPECTION DATE: 6/22/15  
WEATHER: 81°F, A Few clouds  
INSPECTED BY: D. West, K. Homza

Location/ Condition	(y/n)	Change (y/n)	Comments
Low Point, A dike*			
Flow	N	N	1012 hrs. No standing water behind sand bagged
Erosion	r	N	area. Sand bags and rip rap in place.
Low Point, B dike*			
Flow	N	r	1016 hrs. No standing water behind sand bagged
Erosion	N	N	area. Sand bags and rip rap in place.
Outfall water surface El. (top of stoplogs to water)			1020 hrs. No standing water at concrete weir. Water is slightly seeping into NW corner of weir. 47" from ground to top of weir.

\* See figure below.

Additional Comments (Note any changes observed along the embankment crest or downstream slope observed from the crest.): Rainfall event of 1.53" beginning 6/19 ~2330 hrs ending 6/21 ~0800hrs. Standing water at base of the slope between A and B.

HT 1200 hrs, LT 1803 hrs

